

01-09-90

213-2

The contractor's attention is directed to the following consideration in regard to removal and replacement of topsoil in borrow areas: Quantities estimated for topsoil are calculated on the basis of a uniform removal of topsoil to a depth of 12 inches. The material removed is to be spread uniformly to a minimum depth of 8 inches over the borrow area upon completion of excavation work.