




REVISED 11-09 - PILING NO. & DESIGN LOADS CHANGED TO LRFD. ABUT. WING SHAPE CHANGED.



PART SECTION B-B
(FOR STEEL H-PIILING)

NOTE: THE SPIRAL AT THE TOP OF EACH PILE TO BE 7 TURNS OF NO. 2 BAR, 21" DIAMETER, 3" PITCH WITH 3 - 1/4" x 1/4" x 1/4" SPACERS PUNCHED TO HOLD SPIRAL.



PART SECTION B-B
(FOR WOOD PILING)

WOOD PILING NOTE:
AFTER PILES ARE CUT OFF, THE UPPER 3', EXCEPT AS SHOWN, IS TO BE WRAPPED WITH A DOUBLE THICKNESS OF RUG PADDING HELD IN PLACE BY TACKING WITH GALVANIZED ROOFING NAILS AND WRAPPED WITH #14 GAUGE GALVANIZED WIRE AT A 4" PITCH, CARE IS TO BE TAKEN NOT TO DAMAGE PADDING WHEN PLACING CONCRETE. RUG PADDING MAY BE EITHER OF THE FOLLOWING:
(1) HAIR AND JUTE RUG PADDING, RUBBERIZED ON BOTH SIDES, AND WEIGHING NOT LESS THAN 47 OZ. PER SQ. YD.
(2) BONDED URETHANE OR BONDED POLYFOAM WITH A MINIMUM DENSITY OF 5 LBS. PER CU. FT. AND SHALL BE AT LEAST 1/2 IN. THICK. (MATERIAL LESS THAN 1/2 IN. IN THICKNESS MAY BE USED, BUT WILL REQUIRE ADDITIONAL WRAPS FOR A TOTAL OF AT LEAST ONE INCH.)

ABUTMENT NOTES:
MINIMUM CLEAR DISTANCE FROM FACE OF CONCRETE TO NEAR REINFORCING BAR IS TO BE 2" UNLESS OTHERWISE NOTED OR SHOWN.
IF NECESSARY TO PREVENT DAMAGE TO THE END OF THE BRIDGE DECK OR BACKWALL FROM CONSTRUCTION EQUIPMENT, AN APPROPRIATE METHOD OF PROTECTION APPROVED BY THE ENGINEER SHALL BE PROVIDED BY THE BRIDGE CONTRACTOR AT NO EXTRA COST TO THE COUNTY OR STATE.
ABUTMENT PILES ARE TO BE DRIVEN TO THE DESIGN BEARING VALUE AS GIVEN IN THE ABUTMENT PILE SPACING TABLE.
PLACE 5h2 BAR AT 1:6 SLOPE TO MATCH TRAFFIC SIDE OF ABUTMENT WING FACE. (BOTH SIDES TYPICAL.)
BARRIER RAIL NOT SHOWN IN DETAILS.

ABUTMENT PILE SPACING		138'-10"	151'-4"	163'-10"	176'-4"	188'-10"
WITH WOOD PILES	"A" PILE SPACES	14	15	16	16	17
	"B" (FT. - IN.)	3'-1	2'-11	2'-9	2'-9	2'-7
	"C" (FT. - IN.)	2'-10	2'-6 1/2	2'-5	2'-5	2'-5 1/2
	"D" EQUAL SPACES	1	1	1	1	1
	NO. OF PILES PER ABUT.	15	16	17	17	18
WITH STEEL H-PILES	1 PILE BEARING (TONS)	20	19	19	20	20
	2 STRENGTH I DESIGN LOAD (KIPS)	56	55	55	57	56
	"A" PILE SPACES	6	6	6	7	7
	"B" (FT. - IN.)	7'-4	7'-4	7'-4	6'-3	6'-3
	"C" (FT. - IN.)	2'-5	2'-5	2'-5	2'-6 1/2	2'-6 1/2
	"D" EQUAL SPACES	5	5	5	4	4
	NO. OF PILES PER ABUT.	7	7	7	8	8
	1 PILE BEARING (TONS)	45	47	50	45	47
	2 STRENGTH I DESIGN LOAD (KIPS)	130	136	145	132	136

- ① FOR DETERMINING ACTUAL PILE LENGTHS IN FIELD.
- ② FOR ESTIMATING PILE LENGTHS USING AASHTO LRFD SPECIFICATIONS.

LATEST REVISION DATE
11-09

APPROVED BY BRIDGE ENGINEER
Thomas C. McQuinn

STANDARD DESIGN - 44' ROADWAY, THREE SPAN BRIDGE
PRETENSIONED PRESTRESSED
CONCRETE BEAM BRIDGES
MARCH, 2007

ABUTMENT DETAILS
15° SKEW A & B BEAMS

H44-11-07