SINGLE SPAN REINFORCED CONCRETE BOX CULVERT STANDARDS

GENERAL NOTES:	INDEX FOR CULVERT STANDARDS:			
I. THE RCB CULVERT SECTIONS ARE DESIGNED FOR HS20-44 LIVE LOAD AND EARTH FILLS OF VARYING HEIGHTS. 2. FOR VERTICAL LOADS THE WEIGHT OF EARTH IS ASSUMED AS 140 pcf.	RCB 3-1-89	CULVERT BARREL DETAILS, VARIABLE DIMENSIONS AND QUANTITIES TABLE - 3'SPAN.	FWH 30-1-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 30° SKEW - 12'& 10'SPANS.
2. FOR VERTICAL LOADS THE MEIGHT OF EARTH IS ASSUMED AS 140 PCT. 2 = 170 FOR CRACK CONTROL. 3. LATERAL EARTH LOADS EQUIVALENT FLUID PRESSURE IS ASSUMED AS 36 Def/FT.	RCB 4-1-89	CULVERT BARREL DETAILS, VARIABLE DIMENSIONS AND QUANTITIES TABLE - 4'SPAN.	FWH 30-2-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 30° SKEW - 8' & 6' SPANS.
AS 30 PST/F/. AMETAL BAR CHAIRS SPACED AT NOT OVER 3'-0 C-C IN EITHER DIRECTION ARE TO BE USED TO SUPPORT ALL SLAB AND FLOOR STEEL AS OUTLINED IN THE STANDARD SPECIFICATIONS (ARTICLE 2404.07).	RCB 5-1-87	CULVERT BARREL DETAILS, VARIABLE DIMENSIONS AND QUANTITIES TABLE - 5'SPAN.	FWH 30-3-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 30° SKEW - 5'SPAN.
THE CLEAR DISTANCE FROM FACE OF CONCRETE TO NEAR EDGE OR END OF REINFORCING BAR TO BE 2" UNLESS OTHERWISE NOTED.	RCB 6-I-87	CULVERT BARREL DETAILS, VARIABLE DIMENSIONS AND QUANTITIES TABLE - 6'SPAN.	FWH 30-4-87	DIMENSION TABLE.
6. LONGITUDINAL REINFORCING IS NOT TO EXTEND THRU THE CONSTRUCTION JOINTS, EXCEPT FOR 5-1 DOWEL BARS IN SLAB. 7. ALL REINFORCING STEEL IS TO BE SECURELY WIRED IN PLACE	RCB 8-1-87	CULVERT BARREL DETAILS, VARIABLE DIMENSIONS AND QUANTITIES TABLE - 8'SPAN.	FWH 30-5-87	CURTAIN WALL DETAILS AND PLAN VIEW - APRON REINFORCING, TOP & BOTTOM.
BEFORE THE CONCRETE IS POURED ACCORDING TO ARTICLE 2404.03, D, OF THE STANDARD SPECIFICATIONS. 8, FLOOR OF BARREL IS TO BE FINISHED SMOOTH, SIDES OF FOOTING	RCB 10-1-87	CULVERT BARREL DETAILS, VARIABLE DIMENSIONS AND QUANTITIES TABLE - 10' SPAN.	FWH 30-6-87	TYPICAL VIEW - FRONT & BACK FACE REINFORCING, SHORT & LONG WINGWALL, TYPICAL SECTION - NEAR CENTER OF APRON, TOP OF WINGWALL DETAILS AND SECTION THRU PARAPET.
ARE TO BE FORMED TO INSURE CORRECT LINE AND GRADE. 9. ALL EXPOSED CORNERS 90° OR SHAPPER TO BE FILLETED WITH A ¾" DRESSED AND BEVELED STRIP.	RCB 12-1-87	CULVERT BARREL DETAILS, VARIABLE DIMENSIONS AND QUANTITIES TABLE - 12' SPAN.	FWH 45-1-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 45° SKEW - 12' & 10' SPANS.
IO. THE PERMISSIBLE CONSTRUCTION JOINT AT THE TOP OF THE WALLS MAY BE LOWERED AT THE CONTRACTOR'S OPTION WITH ENGINEER'S APPROVAL. II. THE REINFORCEMENT SUPPLIED FOR THIS STRUCTURE SHALL BE	FWH 0-1-87	BENT BAR DETAILS, BILL OF REINFORCING FOR ONE HEADWALL, 0° SKEW - 12'& 10'SPANS.	FWH 45-2-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 45° SKEW - 8'& 6'SPANS.
GRADE 60 REINFORCEMENT IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS. THE DESIGN STRESSES ARE BASED ON GRADE 60 REINFORCEMENT. 12. THE VERTICAL BARS IN THE WALLS MAY BE SPLICED ABOVE THE FOOTING AT THE CONTRACTOR'S OPTION AS FOLLOWS:	FWH 0-2-87	BENT BAR DETAILS, BILL OF REINFORCING FOR ONE HEADWALL,O° SKEW - 8',6',5',4' & 3' SPANS.	FWH 45-3-87	BENT BAR DETAILS, BILL OF REINFORCING FOR ONE HEADWALL, 45° SKEW - 5'SPAN AND CUPTAIN WALL DETAILS - ALL SPANS.
BAR SIZE NUMBER 4 5 6 7 8 9 MINIMUM SPLICE LENGTH 17" 21" 25" 34" 44" 56"	FWH 0-3-87	DIMENSION TABLE.	FWH 45-4-87	DIMENSION TABLE.
THIS SPLICE, IF USED WILL BE AT THE CONTRACTOR'S EXPENSE. 13. REBAR CLEARANCES WILL BE AS FOLLOWS: VERTICAL, TOP 2*	FWH 0-4-87	CURTAIN WALL DETAILS AND PLAN VIEW - APRON REINFORCING, TOP & BOTTOM.	FWH 45-5-87	PLAN VIEW - APRON REINFORCING, TOP & BOTTOM.
VERTICAL, BOTTOM 3", OR 3½" IF THE OVERALL HEIGHT OF THE CULVERT IS NOT TO A FULL INCH TRANSVERSE 2"	FWH 0-5-87	TYPICAL VIEW - FRONT & BACK FACE REINFORCING, SHORT & LONG WINGWALL, TYPICAL SECTION - MEAR CENTER OF APRON, TOP OF WINGWALL DETAILS AND SECTION THRU PARAPET.	FWH 45-6-87	TYPICAL VIEW - FRONT & BACK FACE REINFORCING, SHORT & LONG WINGWALL, TYPICAL SECTION - NEAR CENTER OF APRON, TOP OF WINGWALL DETAILS AND SECTION THRU PARAPET.
EDGE CLEARANCES 2" EXCEPT, TOP OF FLOOR 21" TO NEAR TRANSVERSE REIN BAR OR BOTTOM OF FLOOR 31" TO NEAR TRANSVERSE REINF BAR. 14. ALL CONSTRUCTION JOINTS SHALL BE FORMED WITH A BEVELED	FWH 15-1-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 15° SKEW - 12' & 10' SPANS.	CBJ 1-87	CULVERT BELL JOINT DETAILS AND ESTIMATE OF QUANTITIES TABLE - 3', 4' & 5' SPANS.
KEYWAY EXCEPT AT BELL JOINTS.	FWH 15-2-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 15° SKEW - 8'& 6'SPANS.	CBJ 2-87	CULVERT BELL JOINT DETAILS AND ESTIMATE OF QUANTITIES TABLE - 6' & 8' SPANS.
KEYWAY DIMENSIONS SHOWN ON THE PLANS ARE BASED ON NOMINAL DIMENSIONS UNLESS STATED OTHERWISE. IN ADDITION, THE BEVEL USED ON THE KEYWAY SHALL BE LIMITED TO A MAXIMUM OF IO DEGREES FROM VERTICAL.	FWH 15-3-87	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL, 15° SKEW - 5'SPAN.	CBJ 3-87	CULVERT BELL JOINT DETAILS AND ESTIMATE OF QUANTITIES TABLE - 10' & 12' SPANS.
	FWH 15-4-87	DIMENSION TABLE.	CBJ 4-87	PERMISSIBLE CULVERT BELL JOINT DETAILS.
ALL BEVELED KEYWAYS SHALL BE CENTERED.	FWH 15-5-87	CURTAIN WALL DETAILS AND		
KEYWAY SIZE SHALL BE 2×4 EXCEPT AS FOLLOWS : KEYWAY BETWEEN THE FLOOR AND WALL SHALL BE 2×6 WHEN	· ···· · · · · · · · · · · · · · · · ·	PLAN VIEW - APRON REINFORCING, TOP & BOTTOM.		
THE WALL IS GREATER THAN 10 INCHES WIDE. 15. IF 0' OF FILL IS SPECIFIED, DETAILS FOR PAYING NOTCH AND DESCRIPTION OF SHAPE OF SH	FWH 15-6-87	TYPICAL VIEW - FRONT & BACK FACE REINFORCING, SHORT & LONG WINGWALL, TYPICAL SECTION - NEAR CENTER OF APRON, TOP OF WINGWALL DETAILS		STANDARD DESIGN

SPECIFICATIONS :

DESIGN: AASHTO SERIES OF 1983, EXCEPT AS MODIFIED IN "GENERAL NOTES 2 & 3" ABOVE.
CONSTRUCTION: STANDARD SPECIFICATIONS OF THE IOWA DEPARTMENT

REFERENCE TO EPOXY COATING OF SLAB REINFORCING STEEL, IF APPLICABLE,

OF TRANSPORTATION SPECIFICATION, CURRENT SERIES, PLUS CURRENT SUPPLEMENTAL SPECIFICATIONS AND SPECIAL PROVISIONS.

SHALL BE INCLUDED IN THE FINAL PLANS.

DESIGN STRESSES :

DESIGN STRESSES FOR THE FOLLOWING MATERIALS ARE IN ACCORDANCE WITH THE AASHTO STANDARD SPECIFICATIONS FOR HIGHWAY BRIDGES,

AND SECTION THRU PARAPET.

REINFORCING STEEL IN ACCORDANCE WITH SECTION 8, GRADE 60.
CONCRETE IN ACCORDANCE WITH SECTION 8, f'c = 3,500 PSI.

GENERAL INFORMATION

FOR
REINFORCED CONCRETE BOX CULVERTS

IOWA DEPARTMENT OF TRANSPORTATION - HIGHWAY DIVISION

RCB-GI-87