



- ① For new pipe connections, provide cored opening with flexible pipe connector.
- ② For existing pipe connections, provide an arched opening with a diameter up to 6 inches larger than outside diameter of pipe. Install waterstop around existing pipe. Fill void between pipe and opening with non-shrink grout.
- ③ For additional configurations, maintain a minimum of 12 inches of concrete between vertical edges of pipe openings.
- ④ 12 inch minimum riser height above all pipe openings.

Manhole Diameter (inches)	Maximum Pipe Diameter (inches) for 2 Pipes ③	
	At 180° Separation	At 90° Separation
48	24	18
60	36	24
72	42	30
84	48	36
96	60	42

SUDAS IOWADOT	REVISION
	1   10-21-14
FIGURE 6010.303	STANDARD ROAD PLAN
<b>SW-303</b> SHEET 1 of 1	

REVISIONS: Changed "Chimney Seal" to "Infiltration Barrier".

*Paul D. Wigand* SUDAS DIRECTOR      *Brian Smith* DESIGN METHODS ENGINEER

**SANITARY SEWER MANHOLE  
OVER EXISTING SEWER**

FIGURE 6010.303 SHEET 1 OF 1