



Iowa Department
of Transportation

Highway Division

TRIPLE REINFORCED CONCRETE BOX CULVERT STANDARDS

GENERAL NOTES:

- THE RCB CULVERT SECTIONS ARE DESIGNED FOR HS20-44 LIVE LOAD AND EARTH FILLS OF VARYING HEIGHTS.
- THE MAXIMUM SERVICE LOAD STRESS (ksi) IN THE REINFORCING STEEL FOR CRACK CONTROL SHALL BE:
 $f_{sa} = 170 / \sqrt{dca}$
dc AND a ARE IN INCHES AND INCHES² RESPECTIVELY
- METAL BAR CHAIRS SPACED AT NOT OVER 3'-0" C-C IN EITHER DIRECTION ARE TO BE USED TO SUPPORT ALL SLAB AND FLOOR STEEL AS OUTLINED IN THE STANDARD SPECIFICATIONS (ARTICLE 2404.07).
- THE CLEAR DISTANCE FROM FACE OF CONCRETE TO NEAR EDGE OR END OF REINFORCING BAR TO BE 2" UNLESS OTHERWISE NOTED.
- LONGITUDINAL REINFORCING IS NOT TO EXTEND THRU THE CONSTRUCTION JOINTS, EXCEPT FOR 5#1 DOWEL BARS IN SLAB.
- ALL REINFORCING STEEL IS TO BE SECURELY WIRED IN PLACE BEFORE THE CONCRETE IS POURED ACCORDING TO ARTICLE 2404.03, D, OF THE STANDARD SPECIFICATIONS.
- FLOOR OF BARREL IS TO BE FINISHED SMOOTH. SIDES OF FOOTING ARE TO BE FORMED TO INSURE CORRECT LINE AND GRADE.
- ALL EXPOSED CORNERS 90° OR SHARPER TO BE FILLETED WITH A 3/4" DRESSED AND BEVELED STRIP.
- THE PERMISSIBLE CONSTRUCTION JOINT AT THE TOP OF THE WALLS MAY BE LOWERED AT THE CONTRACTOR'S OPTION WITH ENGINEERS APPROVAL.
- THE REINFORCEMENT SUPPLIED FOR THIS STRUCTURE SHALL BE GRADE 60 REINFORCEMENT IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS. THE DESIGN STRESSES ARE BASED ON 60 GRADE REINFORCEMENT.
- THE VERTICAL BARS IN THE WALLS MAY BE SPLICED ABOVE THE FOOTING AT THE CONTRACTOR'S OPTION AS FOLLOWS:
BAR SIZE NUMBER 4 5 6 7 8
MINIMUM SPLICE LENGTH 21" 26" 31" 43" 55"
THIS SPLICE, IF USED WILL BE AT THE CONTRACTOR'S EXPENSE.
- REINFORCING BAR CLEARANCES WILL BE AS FOLLOWS:
EDGE CLEARANCES: 2" EXCEPT
TOP OF FLOOR 2 1/4" TO NEAR TRANSV. REINF. BAR
BOTTOM OF FLOOR 3 1/2" TO NEAR TRANSV. REINF. BAR
END CLEARANCES:
VERTICAL TOP 2"
VERTICAL BOTTOM 3" OR 3 1/2" IF OVERALL HEIGHT OF THE
CULVERT IN NOT TO A FULL INCH
TRANSVERSE 2"
13. ALL CONSTRUCTION JOINTS SHALL BE FORMED WITH A BEVELED KEYWAY EXCEPT AT BELL JOINTS.

KEYWAY DIMENSIONS SHOWN ON THE PLANS ARE BASED ON NOMINAL DIMENSIONS UNLESS STATED OTHERWISE. IN ADDITION, THE BEVEL USED ON THE KEYWAY SHALL BE LIMITED TO A MAXIMUM OF 10 DEGREES FROM VERTICAL.

ALL BEVELED KEYWAYS SHALL BE CENTERED.

KEYWAY SIZE SHALL BE 2x4 EXCEPT AS FOLLOWS :
KEYWAY BETWEEN THE FLOOR AND WALL SHALL BE 2x6 WHEN THE WALL IS GREATER THAN 10 INCHES WIDE.
- IF 0 FT. OF FILL IS SPECIFIED, DETAILS FOR PAVING NOTCH AND REFERENCE TO EPOXY COATING OF SLAB REINFORCING STEEL, IF APPLICABLE, SHALL BE INCLUDED IN THE FINAL PLANS.
- ALL DIMENSIONS ARE IN FEET AND INCHES UNLESS OTHERWISE NOTED OR SHOWN.

SPECIFICATIONS:

DESIGN: AASHTO SERIES OF 1992, EXCEPT AS MODIFIED IN GENERAL NOTES 2 ABOVE.
CONSTRUCTION: STANDARD SPECIFICATIONS OF THE IOWA DEPARTMENT OF TRANSPORTATION SPECIFICATION, CURRENT SERIES, PLUS CURRENT SUPPLEMENTAL SPECIFICATIONS AND SPECIAL PROVISIONS.

DESIGN STRESSES:

DESIGN STRESSES FOR THE FOLLOWING MATERIALS ARE IN ACCORDANCE WITH THE AASHTO STANDARD SPECIFICATIONS FOR HIGHWAY BRIDGES, SERIES OF 1992.
REINFORCING STEEL IN ACCORDANCE WITH SECTION 8, GRADE 60.
CONCRETE IN ACCORDANCE WITH SECTION 8, f'c = 3,500 PSI.

INDEX FOR CULVERT STANDARDS

TRRCB 10-6-01	CULVERT BARREL DETAILS - 10' x 6' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 30-1-01	DIMENSION TABLE - 30° SKEW
TRRCB 10-8-01	CULVERT BARREL DETAILS - 10' x 8' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 30-2-01	PLAN VIEW - APRON REINFORCING, TOP AND BOTTOM
TRRCB 10-10-01	CULVERT BARREL DETAILS - 10' x 10' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 30-3-01	TYPICAL SECTION - NEAR CENTER OF APRON, CURTAIN WALL PLAN AND SECTION AND DETAILS
TRRCB 10-12-01	CULVERT BARREL DETAILS - 10' x 12' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 30-4-01	TYPICAL VIEW - FRONT AND BACK FACE REINFORCING, WINGWALLS, CENTER WALL
TRRCB 12-6-01	CULVERT BARREL DETAILS - 12' x 6' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 30-5-01	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL 30° SKEW, 10'-0 AND 12'-0 SPANS
TRRCB 12-8-01	CULVERT BARREL DETAILS - 12' x 8' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 45-1-01	DIMENSION TABLE - 45° SKEW
TRRCB 12-10-01	CULVERT BARREL DETAILS - 12' x 10' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 45-2-01	PLAN VIEW - TOP APRON REINFORCING
TRRCB 12-12-01	CULVERT BARREL DETAILS - 12' x 12' VARIABLE DIMENSIONS AND QUANTITIES TABLE	TRH 45-3-01	PLAN VIEW - BOTTOM APRON REINFORCING
TRRCB 2-01	CULVERT BARREL DETAILS - PLAN	TRH 45-4-01	TYPICAL SECTION - NEAR CENTER OF APRON, CURTAIN WALL PLAN AND SECTION AND DETAILS
TRH 0-1-01	DIMENSION TABLE - 0° SKEW	TRH 45-5-01	TYPICAL VIEW - FRONT AND BACK FACE REINFORCING, WINGWALLS, CENTER WALLS
TRH 0-2-01	PLAN VIEW - APRON REINFORCING, TOP AND BOTTOM	TRH 45-6-01	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL 45° SKEW, 10'-0 AND 12'-0 SPANS
TRH 0-3-01	TYPICAL SECTION - NEAR CENTER OF APRON, CURTAIN WALL PLAN AND SECTION AND DETAILS	TRCBJ 1-01	CULVERT BELL JOINT DETAILS AND ESTIMATE OF QUANTITIES TABLE - 10'-0 SPAN
TRH 0-4-01	TYPICAL VIEW - FRONT AND BACK FACE REINFORCING, WINGWALLS, CENTER WALLS	TRCBJ 2-01	CULVERT BELL JOINT DETAILS AND ESTIMATE OF QUANTITIES TABLE - 12'-0 SPAN
TRH 0-5-01	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL 0° SKEW, 10'-0 AND 12'-0 SPANS	TRCBJ 3-01	PERMISSIBLE CULVERT BELL JOINT DETAILS
TRH 15-1-01	DIMENSION TABLE - 15° SKEW		
TRH 15-2-01	PLAN VIEW - APRON REINFORCING, TOP AND BOTTOM		
TRH 15-3-01	TYPICAL SECTION - NEAR CENTER OF APRON, CURTAIN WALL PLAN AND SECTION AND DETAILS		
TRH 15-4-01	TYPICAL VIEW - FRONT AND BACK FACE REINFORCING, WINGWALLS, CENTER WALL		
TRH 15-5-01	BENT BAR DETAILS AND BILL OF REINFORCING FOR ONE HEADWALL 15° SKEW, 10'-0 AND 12'-0 SPANS		

CORRECTION 08-10 - ARTICLE 2404.06 CHANGED TO 2404.03, D, IN GENERAL NOTES. ENGLISH SIGNED TRIPLE CULVERTS.DGN - TRRCB-GI-01 - 09-01 THIS SHEET ISSUED.

LATEST REVISION DATE : 08-10	APPROVED BY : 	STANDARD DESIGN
		GENERAL INFORMATION
		FOR TRIPLE REINFORCED CONCRETE BOX CULVERTS
		IOWA DEPARTMENT OF TRANSPORTATION - HIGHWAY DIVISION SEPT., 2001
		TRRCB-GI-01