



PLAN VIEW

- ① Fill annular space with non-shrink grout.
- ② Outlets through intake walls to be CMP; corrugated, double-walled HDPE; or PVC.
- ③ Extend outlet pipe into structure as required to install removable rodent guard grate. Rodent guard grates complying with Iowa DOT Materials I.M. 443.01 are required for pipes 6 inches and smaller.

	REVISION
	2 10-21-14
	4040.233
SHEET 1 of 1	
SUDAS Standard Specifications	
SUBDRAIN OUTLETS	