

**Security Camera Installation for Various DL Stations
Proposal 12903
Iowa Dot Response to Vendor RFP Questions**

Set 2

1. On the existing access and security systems, is there already outputs that we can tie to and are programmed? Or if there needs to be some programming on the DSX system for the outputs would the DOT be able to do that?

We don't believe there are Moxa's on site for the cameras so an interface between the cameras and DSX will need to be included. This should be in the specifications.

2. Do you know or could you find out if there will be any programming of the DSX system needed?

Yes, you will need to have programming for the cameras into the existing DSX system.

3. Would you be interested in seeing a potential substitution to the spec'd Avigilon systems?

No substitutions.

4. Network Switch specification requested.

That was included by error and is now removed from Spec Section:
2.04 Accessories

B. Provide network switches as required for network connections to system components.

C. Provide cables as indicated for required connections between system components.

D. Branch video cable: Cat6 blue patch cable