

December 17, 2014

ADDENDUM NO.1
to the
Iowa Department of Transportation
Proposal No.13294
For South wing base and stair covering
Letting Date: December 30, 2014

Notice To Bidders:

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

CORRECTION: Bid title should be "Staircase Renovation in south wing at DOT complex"

CLARIFICATION:

The walls and flooring material to be covered is terrazzo. The stairs are poured concrete with cove angles that will need to be squared. The terrazzo on the stairs will be covered with linoleum and carpeted (see drawing) and is not part of this bid request.

Approximately 50 LF of 20" either solid oak hardwood or oak veneer plywood materials will be needed to cover vertical terrazzo surfaces around stairs and up sidewall. This does not include raisers against stairway.

Z-clip installation would be acceptable on stairs for covering terrazzo.

End result to be a professional look with finished edges.

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

Company Name (please print)

Date

Signature

Sincerely,



Rhonda Ruark, Purchasing Agent
Phone No. 515-239-(phone) Fax No. 515-239-1538
rhonda.ruark@dot.iowa.gov

Purchasing Section
800 Lincoln Way, Ames, Iowa 50010

P: 515-239-1310 F: 515-239-1538
DOT.purchasing@dot.iowa.gov