

3/24/15

ADDENDUM NO. 1
to the
Iowa Department of Transportation
Proposal No. 13816
For Coralville and Ottumwa HVAC Replacement
Letting Date: 3/25/15

Notice To Bidders:

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

ADDITIONS:

1) Coralville Exhaust System Improvements:

Sheet M-1: The existing exhaust fan will remain as shown on sheet M-1 connected to the Hose Reel F-4B and Swivel Boom and capture arm F-4C.

Provide the following for the Tag listed on the drawings as F-4B and F-4C:

F-4B: Monoxivent Exhaust Hose Reel, Model 9246, Spring operated, 24' of 6" diameter 4000 series high temperature hose with Model TPA-RB-6 Rubber adapter with lifting Sleeve, Magnet and building in spring hinge adapter; Model LP-10-H Lifting Pole.

F-4C: Monoxivent, Model 15714-BA Swivel Boom with Capture Arm; 7' long, 6" diameter aluminum swivel boom, 14' long 6" diameter flexible extraction arm with series 6000 weld proof hose and polycarbonate collection hood with handle and damper.

2) Ottumwa Exhaust System Improvements:

Sheet M-1: Refer to F-4 in the Fan Schedule for the exhaust fan model, capacity, rating, and electrical requirements which exhausts the Swivel Boom and capture arm F-4B and Hose Reel F-4C.

Provide the following for the Tag listed on the drawings as F-4B and F-4C:

F-4B: Monoxivent, Model 15714-BA Swivel Boom with Capture Arm; 7' long, 6" diameter aluminum swivel boom, 14' long 6" diameter flexible extraction arm with series 6000 weld proof hose and polycarbonate collection hood with handle and damper.

F-4C: Monoxivent Exhaust Hose Reel, Model 9246, Spring operated, 24' of 6" diameter 4000 series high temperature hose with Model TPA-RB-6 Rubber adapter with lifting Sleeve, Magnet and building in spring hinge adapter; Model LP-10-H Lifting Pole..

3) Letting Date Change:

The Iowa DOT has made the decision to change the letting date for this request to April 1, 2015 at 1:00pm.

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

Company Name *(please print)*

Date

Signature

Sincerely,

(Name), Purchasing Agent (Title)
Iowa Department of Transportation
Purchasing Section
Phone No. 515-239-(phone) Fax No. 515-239-1538
DOT.purchasing@dot.iowa.gov