

July 21, 2015:

**ADDENDUM NO. 3
to the
Iowa Department of Transportation
Proposal No. 14648
North Des Moines Maintenance Facility
Letting Date: 7/22/2015**

Notice To Bidders:

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

CHANGES:

Section 08 3613

Sectional Doors Page 3

2.05 Electrical Characteristics

A-1 lists 1/3 hp operator. Others have been 3/4 hp. Please clarify.

Provide ¾ HP operator for the overhead doors in lieu of the 1/3 HP operators specified.

083613 UNDER THE WASH BAY / BRINE BUILDING SPECS. THEY CALL FOR STANDARD HEADROOM LIFT I THOUGHT THE WASH BAY DOORS MAY GO HIGH LIFT AS THE OTHER DOORS IN THAT BUILDING (PER DRAWING BUT NOTHING IS LISTED IN THE SPECIFICATIONS)

WHAT DO WE BID HIGH LIFT OR STANDARD HEADROOM TRACK?

Provide High lift doors for the Wash Bay and Brine Building doors.

ELECTRICAL OPERATIONS (TYPE 1 OPERATORS)

2.05 A.

1. 1/3 HP GENERALY A 3/4 HP IS REQUIRED WITH A SOENOID BRAKE

ARE YOU SURE YOU WANT 1/3 HP?

Provide ¾ HP operator for the overhead doors in lieu of the 1/3 HP operators specified.

2.03 DOOR COMPONENTS

B & C DON'T THEY CONTRADICT EACH OTHER

THE DRAWINGS SHOW 3 LITES IN THE 3RD SECTION 16' WIDE DOORS ARE SPACED TO HAVE 4 LITES 3 LITES WOULD **NOT** BE SPACED EQUALLY DO YOU WANT TO GO WITH 2 OR 4 LITES

DO YOU WANT SOLID SHAFTS IN THE MAINTENACE GARAGE

DOOR COMPONENTS

2.03 D

ARE YOU SURE YOU WANT STAINLESS STEEL CABLE IN THE MAINTENANCE GARAGE AS THIS IS SOMETHING NEW THAT YOU HAVE NEVER DONE BEFORE BUT THEY HAVE ALWAYS

BEEN USED ON THE POLYCARBONATE DOORS

Stainless steel cabling is only required with the Wash Bay doors and the Brine Building overhead doors.

Pre cast insulated panels with R18 value is acceptable.

ADDITIONS: Section 08 3613 Paragraph 2.01.A: **Add Overhead Door to list of acceptable manufacturers.**

Section 10 2113.19, Paragraph 2.01.A: **Add AMPCO Products, LLC to list of acceptable manufacturers.**

Brae requests Watts Radiant can offer PERT Tubing and Stainless Steel Manifolds for the North Maintenance Facility. **Denied the piping does not meet the hydrostatic pressure requirements.**

Radiant Heating Hydronic Piping Substitution. **Denied does not meet the specifications as they are written and cannot be approved as an acceptable substitution.**

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

Company Name *(please print)*

Date

Signature

Sincerely,

Jody McNaughton, Purchasing Agent III
Phone No. 515-239-1298 Fax No. 515-239-1538
Jody.McNaughton@dot.iowa.gov