

July 22, 2015:

**ADDENDUM NO. 4  
to the  
Iowa Department of Transportation  
Proposal No. 14648  
For North Des Moines Maintenance Facility  
Letting Date: 6/22/2015**

**Notice To Bidders:**

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

**CHANGE:**

**ADDITIONS:**

**Clarifications:**

**Structural Plans are currently designed with flat precast roof deck. Detail 7/A11 shows a sloped roof deck. Roofing contractors are to bid project based on a flat roof deck with tapered insulation.**

**Brae Request: Please add MPC Precast to DOT list of acceptable precast suppliers.**

*Request is not approved MPC panels do not meet our insulation precast specifications.*

**Brae Request: Exception to specification Part 2.9, Paragraphs B (3), C & D. Automatic dampers, interior lights and convenience outlets are not factory enclosure options in this kW range. Bidder Proposes to furnish in lieu of above: Fixed louvers.**

*Request is not approved as specified automatic dampers are required.*

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

\_\_\_\_\_  
Company Name (*please print*)

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

Sincerely,

Jody McNaughton, Purchasing Agent III  
Phone No. 515-239-1298 Fax No. 515-239-1538  
Jody.McNaughton@dot.iowa.gov

**Purchasing Section**  
**800 Lincoln Way, Ames, Iowa 50010**

**P: 515-239-1310 F: 515-239-1538**  
**[DOT.purchasing@dot.iowa.gov](mailto:DOT.purchasing@dot.iowa.gov)**