

**Proposal 14772– Warehouse Tuck Pointing project
Questions and Responses Set 1**

East side, A, B, & C Bays

Q1) What do you mean by repair holes in light fixture.

R1) These are actually old speakers, the speaker plates will be removed and we will need the holes fixed.

East side, A, B, & C Bays

Q2) Remove black caulking by receiving door and re-caulk per specifications. What exactly does this mean?

R2) Cosmetic fix we will need the old black caulking removed and it will not need to be re-caulked unless it is an area that could potentially leak.

East side, A, B, & C Bays

Q3) Replacement of soulders and siles.

R3) This replacement is only in areas of suggnificant damage to siles and soulders. If the damage to any bricks in the specified areas is larger than a thumb print then we will need it repaired.

Ebay

Q4) Repair drain

R4) There are 2 vent locations on the east side by Ebay. These just need cleaned up and recaulked.

North Side

Q5) Can we block the printing entrance for a couple days to work in this area?

R5) Yes

West side

Q6) Which column are we replacing?

R6) The column being replaced is the SW corner column of the building.

Q7) The lentels are steel are we replacing all of them?

R7) There are no lentel repairs needed.

Q8) In lieu of a check can a bid bond be submitted for the proposal guarantee?

R8) Refer to Terms and Conditions Formal section A Bid proposal, 3 Proposal Guarentee

Photo's are attached of specific areas to help clarify Q2 Q3, Window sile (only siles needing to be repaired such as this photo)., Q1, Q4








Shipping and
Customer
Service

BAY
E





Shipping and
Customer
Service

BAY
E

