

August 03, 2015:

**ADDENDUM NO. 1
to the
Iowa Department of Transportation
Proposal No. 14887
For District 6 Training room remodel
Letting Date: 8/19/2015**

Notice To Bidders:

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

CHANGE: . Regarding the data box. Contractor is to install a low voltage mud ring instead of a box. These are plastic and have no back to them. Place the end of the conduit 1 inch over the rind so it does not interfere with our jack modules. Contractor can stub the other end of the conduit above the tile ceiling with a pull string routed through the conduit.

ADDITIONS:

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

Company Name (*please print*)

Date

Signature

Sincerely,

Jody McNaughton, Purchasing Agent III
Phone No. 515-239-1298 Fax No. 515-239-1538
Jody.McNaughton@dot.iowa.gov