

**Proposal 15285 New Construction for Des Moines North Maintenance Facility, Brine, Pole and Hoop Bldg.
Questions and Responses Set 1**

Q1) The specifications for this job call for Fixed Encompass by Pella Vinyl Windows. The plans show window types W1, W2 and W3 and the window schedule on sheet A-16 being operable aluminum windows. Are any of the windows on this job to be Encompass Vinyl Windows, and if so, are they to operate?

R1) The Vinyl window specification is titled: “Specification Section 08 5313- Vinyl Windows for Brine Building”. The Fixed Encompass Pella Vinyl Window is one of the vinyl window manufacturers specified for the Brine Building which has the size and location noted on the floor plan on sheet BA-1. The window in the brine building will not be operable.