

January 5, 2016

**ADDENDUM NO.3**  
to the  
**Salt Dome Roof Restorations for 8 Maintenance Garage Locations in Iowa**  
**Iowa Department of Transportation**  
**For: Proposal 15535**  
**Letting Date: 01/06/2016**

**Notice To Bidders:**

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

**CHANGES:** This proposal has been extended until till **January 20, 2016**

**Specifications:**

**Section 07 5700 (12-21-2015), Paragraph 1.07:** Delete Paragraph 1.07 Warranty. 10 year Warranty is no longer required.

**Section 07 5700 (12-21-2015), Paragraph 2.01.A.1:** Neogard Permthane II FR System is no longer the Basis of Design. Neogard, Permthane Aliphatic, and Greenshield Aromatic Urethane Coating System are acceptable Manufacturers.

**Section 07 5700 (12-21-2015), Paragraph 3.03.B:** Change Paragraph B to read as follows: Place insulation to 1 inch thickness minimum or to thickness recommended by Urethane Coated Roofing System Manufacturer.

**Section 07 5700 (12-21-2015), Paragraph 3.05.A:** Change Paragraph to read as follows: Install urethane two or three part over coating with top coat per Urethane Coated Roofing System Manufacturer's recommendations to a minimum thickness of 36 dry mils.

**Drawings:**

**Hanlontown Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised Sheet A-1R dated 1-4-2016.

**Desoto Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised Sheet A-1R dated 1-4-2016.

**Sidney Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised Sheet A-1R dated 1-4-2016.

**West Burlington Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised sheet A-1R dated 1-4-2016.

**Tipton Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised Sheet A-1R dated A-1R dated 1-4-2016.

**Anamosa Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised Sheet A-1R dated 1-4-2016.

**Marion Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised Sheet A-1R dated 1-4-2016.

**Davenport Salt Dome Roof Restoration, Sheet A-1:** Replace Sheet A-1 with revised Sheet A-1R dated 1-4-2016.

**ADDITIONS:**

**CLARIFICATIONS:**

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

\_\_\_\_\_  
Company Name (*please print*)

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

Sincerely,

Jody McNaughton, Purchasing Agent III  
Phone No. 515-239-1298 Fax No. 515-239-1538  
Jody.McNaughton@dot.iowa.gov