

January 5, 2016

ADDENDUM NO.9
to the
Ames Complex Repair Shop Restroom Remodel Building 5 & 6
Iowa Department of Transportation
For: Proposal 15581
Letting Date: 01/13/2016

Notice To Bidders:

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

CHANGE: Section 09 6500 Part 2 Products

2.01 Is now titled Tile Flooring and includes the following

A. Linoleum Tile: Homogeneous wear layer bonded to backing, with color and pattern through wear layer thickness:

1. **Minimum Requirements: Comply with ASTM F2195, Type corresponding to type specified.**
2. **Backing: Synthetic fabric.**
3. **Wear Layer Thickness: 0.098 inch, minimum, excluding backing.**
4. **Tile Size: 20 x 20 inches.**
5. **Pattern: Marbleized.**
6. **Color: As selected from standard colors**
7. **Manufacturers:**
 - a. **Forbo Flooring, Inc; Marmoleum: www.forboflooringna.com.**
 - b. **Substitutions: See Section 01 6000 - Product Requirements.**

2.02 Is now titled Resilient Base

2.03 Is now titled Accessories

ADDITIONS:

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

Company Name (*please print*)

Date

Signature

Sincerely,
Jody McNaughton, Purchasing Agent III
Phone No. 515-239-1298 Fax No. 515-239-1538
Jody.McNaughton@dot.iowa.gov

Purchasing Section
800 Lincoln Way, Ames, Iowa 50010

P: 515-239-1310 F: 515-239-1538
DOT.purchasing@dot.iowa.gov

**SECTION 09 6500
RESILIENT FLOORING**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Resilient tile flooring.
- B. Resilient base.
- C. Installation accessories.

1.02 REFERENCE STANDARDS

- A. ASTM F1861 - Standard Specification for Resilient Wall Base; 2008 (Reapproved 2012)e1.
- B. ASTM F2195 - Standard Specification for Linoleum Floor Tile; 2013.
- C. RFCI (RWP) - Recommended Work Practices for Removal of Resilient Floor Coverings; Resilient Floor Covering Institute; 1998.

1.03 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Selection Samples: Submit manufacturer's complete set of color samples for Architect's initial selection.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Protect roll materials from damage by storing on end.

1.05 FIELD CONDITIONS

- A. Maintain temperature in storage area between 55 degrees F and 90 degrees F.
- B. Store materials for not less than 48 hours prior to installation in area of installation at a temperature of 70 degrees F to achieve temperature stability. Thereafter, maintain conditions above 55 degrees F.

PART 2 PRODUCTS

2.01 TILE FLOORING

- A. Linoleum Tile: Homogeneous wear layer bonded to backing, with color and pattern through wear layer thickness:
 - 1. Minimum Requirements: Comply with ASTM F2195, Type corresponding to type specified.
 - 2. Backing: Synthetic fabric.
 - 3. Wear Layer Thickness: 0.098 inch, minimum, excluding backing.
 - 4. Tile Size: 20 x 20 inches.
 - 5. Pattern: Marbleized.
 - 6. Color: As selected from standard colors.
 - 7. Manufacturers:
 - a. Forbo Flooring, Inc; Marmoleum: www.forboflooringna.com.
 - b. Substitutions: See Section 01 6000 - Product Requirements.

2.02 RESILIENT BASE

- A. Resilient Base: ASTM F1861, Type TS rubber, vulcanized thermoset; top set Style B, Cove.
 - 1. Height: 4 inch.
 - 2. Thickness: 0.125 inch thick.
 - 3. Finish: Satin.
 - 4. Color: As indicated on drawings.
 - 5. Manufacturers:
 - a. Burke Flooring: www.burkemercer.com.
 - b. Johnsonite, a Tarkett Company: www.johnsonite.com.

- c. Roppe Corp: www.roppe.com.
- d. Substitutions: See Section 01 6000 - Product Requirements.

2.03 ACCESSORIES

- A. Primers, Adhesives, and Seaming Materials: Waterproof; types recommended by flooring manufacturer.
 - 1. Provide only products having lower volatile organic compound (VOC) content than required by the more stringent of the South Coast Air Quality Management District Rule No.1168 and the Bay Area Air Quality Management District Regulation 8, Rule 51.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces are flat to tolerances acceptable to flooring manufacturer, free of cracks that might telegraph through flooring, clean, dry, and free of curing compounds, surface hardeners, and other chemicals that might interfere with bonding of flooring to substrate.

3.02 PREPARATION

- A. Remove existing resilient flooring and flooring adhesives; follow the recommendations of RFCI Recommended Work Practices for Removal of Resilient Floor Coverings.
- B. Prepare floor substrates as recommended by flooring and adhesive manufacturers.
- C. Clean substrate.

3.03 INSTALLATION

- A. Starting installation constitutes acceptance of sub-floor conditions.
- B. Install in accordance with manufacturer's instructions.
- C. Spread only enough adhesive to permit installation of materials before initial set.
- D. Fit joints tightly.
- E. Scribe flooring to walls, columns, cabinets, floor outlets, and other appurtenances to produce tight joints.

3.04 TILE FLOORING

- A. Mix tile from container to ensure shade variations are consistent when tile is placed, unless manufacturer's instructions say otherwise.

3.05 RESILIENT BASE

- A. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches between joints.
- B. Install base on solid backing. Bond tightly to wall and floor surfaces.

3.06 CLEANING

- A. Remove excess adhesive from floor, base, and wall surfaces without damage.
- B. Clean in accordance with manufacturer's instructions.

3.07 PROTECTION

- A. Prohibit traffic on resilient flooring for 48 hours after installation.

END OF SECTION