

Proposal 15581

Ames DOT Complex Restroom Remodel project for Buildings 5 & 6 Questions and Responses Set 1

Q1) In the Spec book on 01 4000-1 there is a reference for an allowance that refers to sheet 01 2100 but there is no 01 2100 in the specs. As with that in the Spec book for RFB 15581 on 03 300-5, 3.09 A says Iowa DOT will perform quality control tests. Is this referring to concrete testing? Is this testing for both RFB's and just 15581?

**R1) Allowance Section has been added to the Specification, section 01 2
Quality control tests for concrete will be performed by a testing agency
coordinated by the contractor.
Section 03 3000 has been revised to read as such.**