

15602
Electrical upgrade for Centerville Maintenance Garage Brine
Building
Questions and Responses Set 1

Q1. What materials are required for the connectors to the pumps?

R1. 4X stainless steel as listed in the specifications.

Q2. How far do we extend the 1" conduit for future site lighting pipe from the building?
How far do we extend the 2" conduit for future site lighting pipe from the building?

R2. For both: Approximately one foot

Q3. What will be done with the existing electrical service?

R3. Existing electrical service will be capped off and abandoned.

Q4. Proposed service?

R4 North or South according to plans.