

**Proposal 16119**  
**Lighting Installation for 6 Iowa DOT Maintenance Facilities various**  
**locations throughout the State**  
**Questions and Responses Set 1**

**Q1) Bloomfield**

Contractor to provide as per plans  
(Base Bid) supply materials,  
demolition and labor for the following  
fixtures 33 high bay LED ,6 wet LED  
locations high bay, 5 workbench LED,  
3 combination exit/ emergency,  
this includes miscellaneous install and  
materials for circuit new fixtures.

1 Lump/Sum \$ \_\_\_\_\_

**SHOULD BE REQUESTING BASE BID ACCORDING TO FIXTURE SCHEDULE? According to plan schedule WHICH IS T-8 FLOURESCENT FIXTURES BASED ON FIXTURE SCHEDULE PLEASE ADVISE?**

2A

Alt1- E1 for Bloomfield

Contractor to provide alternate (1) as  
per plans LED fixtures as scheduled  
on the Drawings.

All other aspects of the work remain  
the same.

**R1) See Addendum 1**

**Q2 All other locations the keyed notes do not match fixture schedule.**

Electrical Keyed Notes

#4 Demolish and replace the existing fluorescent light fixtures over the work benches with **new LED light fixtures** in the same location....

LIGHT FIXTURE SCHEDULE IS REQUESTING THE FOLLOWING

F3- Linear fluorescent xwl232 MV 2-T8 lamps

Can you please verify if you want what is in the notes or on the fixture schedule?

If you want what is requested in the notes a fixture model number will need to be provided.

**R2)See Addendum 1**

**Q3) Will the accessories in the lighting fixture schedule notes 3,4,5, and 6 be provided by the DOT?**

**R3) No to be provided by Contractor.**

**Q4) The bid form in specs for site #5 Urbana, now has contractor supplying the 18 Type F2 wet location high bay fixtures, but plan fixture schedule on plan page E1 for Urbana still shows the F2 as being supplied by Owner. Can you clarify which is correct.**

**R4) F2 is to be supplied by the Contractor**