

Proposal 16167
Decorah Salt Shed Renovations
Questions and Responses Set 2

Q1) Your scope says 'Monogram double lap' siding. Should that be 'double 4, and is it vinyl?

R1) Double 4" Clapboard Monogram (thicker grade).

Q2) Also the 'Z' cap that will go at the top joint between the lower and upper wall sheathing is available in aluminum or steel. Which should it be?

R2) Aluminum