

**Date: March 28, 2016**

**ADDENDUM NO. 1  
to the  
Iowa Department of Transportation  
Proposal No. 16268  
For  
Electrical Service at Storm Lake Maintenance Garage**

~~Letting Date: 3/31/16~~  
**REVISED LETTING DATE: 4/14/16**

**Notice To Bidders:**

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

**CHANGE: Letting date have been revised from March 31 2016 to April 14, 2016.**

**CLARIFICATIONS TO SECTION 2:**

**DOT owns 6 high pressure sodium lights that are to be installed/not fluorescent lights.  
The two optional outlets & installation are requested and to be included with bid cost.  
No light required at the entry.  
Wire 120**

All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

\_\_\_\_\_  
Company Name *(please print)*

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

Sincerely,



Rhonda Ruark, Purchasing Agent III  
Phone No. 515-239-1285  
[rhonda.ruark@dot.iowa.gov](mailto:rhonda.ruark@dot.iowa.gov)