

Proposal16355
Construction of Brine Buildings for Corning and Avoca Maintenance
Facilities

Questions and Responses Set 3

Q1) In reading Addendum NO.6 we have a question about the change for the contractor to provide a new 2" water meter. We called corning municipal utilities and they said the DOTs water meter is like 4 blocks from the current brine building. They said it doesn't matter where we tie into, it's going to go through their meter. Does the DOT want to meter the water they use to make brine? Can you please clarify?

R1) Yes, because we don't want to have to pay associated drainage fees for the brine-making. (Since it is never drained, - all brine goes on the roads.)