

Proposal 16424
Lighting upgrade for Davenport RCE Building
Questions and Responses Set 2

Q1) In looking at the fixtures again and noted the existing fixtures are T12 lamps. It appears the intent is to put in a single 4-Lamp T8 ballast and (4) T8 LED ballast compatible tubes to upgrade the fixture without disturbing the ceiling. Does the state want the lamp holders / tombstones replaced as well or are we to reuse the existing lamp holders?

R1) We want a single 2-Lamp ballast and (2) LED tubes per fixture. Reuse existing lamp holders.

Q2) Is the state open to alternative retrofit options that also do not break the ceiling plane?

R2) Not at this point, it's too late to get a fair bid.