

Proposal17329
Spencer Roof Replacement at Spencer Maintenance Facility
Questions and Responses Set 2

This is a correction to Question and Response Q5.

Q5) Section 2.05-2.04 we call out the 120-PCI-PSI and they just received notification today that the standard has changed to using 80-PCI-PSI. To use 120-PCI-PSI is a more than what is required do you still want to use 120-PCI-PSI?

R5) We are requiring 120-PCI-PSI as specified.