

Proposal17329
Spencer Roof Replacement at Spencer Maintenance Facility
Questions and Responses Set 3

Q1) Do the corners getting pavers consist of all corners, inside and outside or just the main outside corners?

R1) R1) To include them inside only

Q2) Other than the scupper areas, how do we quote for existing wet roof insulation?

R2) R2) Do not quote for wet insulation. We will deal with it later if necessary.