

**Proposal 17387**  
**Replacement of 2 Rooftop vents at New Hampton Maintenance**  
**Facility**  
**Questions and Responses Set 1**

**Q1)** Section 2.1 (E) Remove and Replace ERM Intake. I am not seeing this on the drawing or anywhere else in the specifications for this project. Can you help on this?

**R1)** This note to read: "(E) Remove and Replace existing EPDM roof membrane flashing at new roof curbs at replaced vent fan locations (2)."