

Proposal 17485
Sand Blasting and Painting of Support Beams at the Malcom DOT
Maintenance Facility
Questions and Responses Set 1

Q1) For the removing the existing paint, is it intended to have all the paint removed from the beams? Or just the material that comes off from the sandblasting/ hand tool cleaning?

R1) The sandblasting is for the columns. We will not touch the beams. Most of the paint should be removed so new paint can adhere to the new surface.